



Supporting attachments appear to be through bolted from the interior to the exterior	
<b>Safety: Window AC units only:</b>	<b>Yes / No / Comments</b>
The unit remains secured when the window is opened, or the window is secured so it cannot be opened accidentally	
The window & frame in which the unit is mounted are in good condition and secure	
The unit is not installed in a window that opens onto a fire escape	
<b>Electrical:</b>	
All electrical cables have an electrical ground	
All electrical cables are in safe condition (no evidence of frayed or spliced cords)	
Electrical penetrations in doors, transoms, or other windows	
<b>Electrical: <u>Window AC units only:</u></b>	
Outlet is appropriate amperage for the unit.	
Unit is plugged into the nearest electrical outlet	
<b>Appearance, Supports &amp; Surrounds:</b>	
Free from flaking paint, rust, mold or mildew	
Neutral colors compatible with exterior façade of the building.	
Insulating or similar materials are not be visible.	
<b>Operation:</b>	
When running the unit is free from excessive vibration or noise.	
Any other installation or equipment conditions noted by the technician.	

## Inspection Report

\_\_\_\_\_ This A/C unit inspected met the building safety inspection requirements

\_\_\_\_\_ This A/C unit does not meet all of the safety inspection requirements.  
The shareholder has been notified of the deficits.

## Declaration

I \_\_\_\_\_ declare that my report is accurate.  
*(Print name (Service Technician))*

I understand that a false declaration may result in the refusal of the Corporation to allow  
\_\_\_\_\_ to provide future services in the building.  
*(Insert A/C service company name)*

Signed: \_\_\_\_\_  
*(Signature of Service Technician)*

Date: \_\_\_\_\_